

# MQ-E3-SO<sub>2</sub> Electrochemical Sensor

# Manual

(Model: MQ-E3-SO<sub>2</sub>)

Version: 1.3

Issue date: 2021-8-24

Taiyuan Tengxing sensor technology Co., Ltd

# **Statement**

- 1. The copyright of instructions belong to Taiyuan Tengxing sensor technology Co., Ltd (hereinafter referred to as the Company), nobody is allowed to copy, translate, spread or store without written approval.
- 2. Thanks for using our product. In order to use the products more smoothly, reduce faults result from inappropriate using, please read the instructions carefully before using and follow the rules suggested strictly. Anyone who don 't follow the instructions, disassemble or change the internal components without permission will afford the loss.
- 3. The color, style and size of the product is subject to the object you received.
- 4. The company follows the idea of scientific and technological progress, make efforts to product-improving and technology-innovating. So we have the right to improve product without prior notice.
- 5. Please make sure it 's valid before using the instructions. Any good suggestions from you is welcomed.
- 6. The instructions should be well kept.

Taiyuan Tengxing sensor technology Co., Ltd

# MQ-E3-SO<sub>2</sub> gas sensor

MQ-E3-SO2 electrochemical sensor detect gas concentration by measuring current based on the electrochemical principle, which utilizes the electrochemical oxidation process of target gas on the working electrode inside the electrolytic cell, the current produced in electrochemical reaction of the target gas are in direct proportion with its concentration while following Faraday law, then concentration of the gas could be get by measuring value of current.

#### 1.Features

- \* Low consumption
- \* High precision
- \* High sensitivity
- \* Wide linear range
- \* Good anti-interference ability
- \* Excellent repeatability and stability


## 2 Application

Widely used in industrial and environmental protection fields

#### 3. Technical Parameter


#### 4. External dimension

Detection gas	SO <sub>2</sub>	
Measurement Range	0∼20ppm	
Max detecting concentration	150ppm	
Sensitivity	(0.6±0.2) μA/ppm	
Resolution ratio	0.1ppm	
Response time (T <sub>90</sub> )	<30\$	
Bias voltage	0mV	
Load resistance (recommend)	10Ω	
Repeatability	<2% output value	
Stability ( / month)	<2%	
Output Linearity	linear	
Zero drift(-20°C∼40°C)	≤0.2ppm	
Storage temperature	-20°C∼50°C	
Storage Humidity	15%∼90%RH	
Pressure range	Standard atmosphere ±10%	
Anticipated using life	2 years(In air)	




#### 5. Characterization


#### Features of Sensitivity, response and recovery time




#### **Data graph of concentration linearity features**




## Zero output upon Variable Temperature




## Sensitivity upon variable temperature



#### 6.Basic circuit





#### 7. Anti-Interference:

MQ-E3-SO<sub>2</sub> sensor also responds to other gases besides target gas. Below are the response characteristics of interferential gases

Gas	Concentration	MQ-E3-SO <sub>2</sub>
СО	200ppm	<2.5ppm
H2S	50ppm	<0.15ppm
CL2	10ppm	<-0.6ppm
C2H4	130ppm	<5ppm
H2	400ppm	<1ppm
C2H5OH	1000ppm	<1.5ppm
NH3	50ppm	<0.1ppm
PH3	20ppm	<3ppm
CH2O	10ppm	<18ppm
С6Н6	100ppm	0ppm
СНЗОН	200ppm	<0.1ppm

#### 8. Application Notes:

- Sensor shall Avoid organic solvent, coatings, medicine, oil and high concentration gases:
- All ME Sensors shall not be encapsulated completely by resin materials, and shall not immerse in oxygen-free environment, otherwise, it will damage the function of sensor;
- All ME sensors shall not be applied in corrosive gas environment, or the sensor will be damaged;
- Please test the sensitivity of gas sensors in clean atmosphere;
- Sensors Shall be avoided to face the gas, which flow directly from front side;

- To avoid to bend and break of pins;
- Blowhole of the sensor should not be blocked and polluted, which will cause the sensitivity decrease;
- Excessive impact or vibration should be avoided;
- Do not use the sensor when the shell is damaged;
- It takes some time for the sensor to return to normal state After applied in high concentration gas;
- Do not take apart the sensor, otherwise electrolyte leakage can cause sensor damage;
- Working electrode and reference electrode of the sensor shall be in short circuit when stored.;
- To preheat over 48hs before using and soldering forbidden;